



# LINGJACK ENGINEERING WORKS PTE LTD

No.1 Woodlands Terrace, Lingjack Industrial Building, Singapore 738471

Tel : (65) 67594163 Fax : (65) 67587513 Web site: [www.combat.com.sg](http://www.combat.com.sg)

Co Reg No. : 199103053M GST Reg no. : M2-0100375-0

Data Sheet No.:90803200

## Bib Nose PRV Flange



Model	DH6i-Flange
Description	Bid Nose Pressure Reducing Valves –Flange type
Inlet	2 1/2" Flanged
Outlet	2 1/2" Instantaneous Female/ BSP Thread
Max. Working Pressure	20 bars ( optional : 30 bar )
Seat Test	22 bars ( optional : 33 bar )
Body Test	30 bars ( optional : 45 bar )
Body Material	Gunmetal BS1400 LG2 / CC491K
Inlet Pressure	5 to 20 bar
Outlet Pressure Static	3.5 bars to 8.0 bars (adjustable)
Pre-Set Outlet Pressure	As per customer requirement
Approval	LPCB approved to BS 5041 Part 1
Optional Materials	Ni Al Br , Titanium Gr C2

