



LINGJACK ENGINEERING WORKS PTE LTD

No.1 Woodlands Terrace, Lingjack Industrial Building, Singapore 738471

Tel : (65) 67594163 Fax : (65) 67587513 Web site: www.combat.com.sg

Co Reg No. : 199103053M GST Reg no. : M2-0100375-0

Data Sheet No.: 90803300

2Way Controllable Pillar Hydrant



Model	PH100C
Description	2 Way Controllable Pillar Hydrant
Test Pressure	25kgf/cm ² (360 PSI) @ 5min
Max. Working Pressure	16kgf/cm ² (230 PSI)
Body Material	Cast Iron
Design	In Compliance with BS750: 1984
Flange Size	100mm PN16 (BS EN 1092-2:1997); Optional: 4" ANSI #150RF
Outlet	Female Instantaneous
Approval	PSB Test Report No. 719165696- MEC-1-TSM

